









# The CANLED Installation Manual General Location







# **APPLICATION**

The CANLED luminaire is an industrial-grade product suitable for harsh and general locations. Installation areas include indoor, outdoor, and wet locations. Frequent exposure to moisture, dirt, corrosion, vibration, and rough usage is common for this product family. As defined by the National Electrical Code (NEC) and the Canadian Electrical Code (CEC), they are suitable for use in the following areas:

Certified to: CSA 22.2 No. 250.0, Conforms To UL 1598 standard

Housing: Copper-free 6061-T6 aluminium with polycarbonate lens

Mounting: 2 x 1/4"-20 screws or bolts

Input Voltage: 12-24VDC (Maximum voltage: 28VDC)

Current (Typ): 0.66A@12VDC | 0.33A@24VDC

Connections: 6' Flying Lead | Black: Negative (-) | White: Postive (+)

Temperature Range: -40° C to +55° C

Ingress Protection: IP66







# WARNING

To avoid the risk of fire, explosion, or electric shock, this product should be installed, inspected, and maintained by a qualified electrician only, in accordance with all applicable electrical codes.



# **WARNING**

To avoid electric shock:

• Be certain electrical power is OFF before and during installation and maintenance.

 Luminaire must be connected to a wiring system with an equipment-grounding conductor.

# **INSTALLATION STEPS**

#### STEP 1:

Inspect shipping package and contents to ensure no damage has occurred during shipping.

#### STEP 2:

Loosen each bracket 1/4"-20 yoke hex bolt (2x) slightly to allow some free movement. Be sure not to loosen too much that they disengage from the CANLED body. This will allow for easier installation and aiming.

#### STEP 3:

Mount fixture to desired location with 2 x 1/4"-20 screws or bolts.

\*See Mounting Dimensions for installations with fixed studs if desired.

#### STEP 4:

Adjust fixture to desired angle and tighten bracket 1/4''-20 yoke bolts.

### STEP 5:


Connect fixture flying lead to DC power supply as per in accordance with all applicable electrical codes.



Black: Negative (-) | White: Positive (+)

#### STEP 6:

Energize fixture.



## MOUNTING DIMENSIONS

